

CONOFLOW REGULATORS & CONTROLS

Division of ITT Grinnell Valve Co., Inc.

P.O. Box 768

St. George, S.C. 29477

(803) 563-9281 TELEX 805062



FOREMOST
IN
CONTROL
ELEMENTS

CONTROL ENGINEERING DATA

Control Engineering Data is intended to provide a single source from which one can determine, in detail, the full scope of the product line. In addition to panel size and construction, it also pro-

vides a listing of available range selections. Control Engineering Data also provides a means of communicating by way of a code number which is fully descriptive of the product selection.

Panels
(Manual Loading Station)

	1-5	6	7	8
Model		Future Options	Operational Feature	Range Selection
PH				

Enter Code Numbers
Selected Here

EXAMPLES:

1) G P H 0 5 X X M

Panel -
Manual Loading Station
Absence of Specification
3-15 PSI (0-100% Cal'br) Range

2) G P H 1 0 X Y K

Panel -
Manual Loading Station
Absence of Specification
Auto - Manual Switch
0-160 PSI Range

1-5
Model

GPH05	=	Panel -	Manual Loading Station (5" x 5½" - Steel Panel)
GPH06	=	Panel -	Manual Loading Station (6" x 6" - Steel Panel)
GPH10	=	Panel -	Manual Loading Station (5" x 10" - Molded Panel) (When the Auto - Manual Switch is specified, the panel dimensions will be 5¼" x 13½" - Steel Panel)

6
Future
Options

X	=	Absence of Specification
---	---	--------------------------

7
Operational
Feature

X	=	Absence of Specification
Y	=	Auto - Manual Switch (GPH10 Only)

8
Range
Selection

Note: Specify Gauge Range when ordering.

B	=	0-15 PSI (Regulator 0-15 PSI)
F	=	0-60 PSI (Regulator 0-50 PSI)
H	=	0-30 PSI (Regulator 0-25 PSI)
J	=	0-100 PSI (Regulator 0-125 PSI)
K	=	0-160 PSI (Regulator 0-125 PSI)
M	=	3-15 PSI - 0-100% Calibrated (Regulator 0-15 PSI)



FOREMOST
IN
CONTROL
ELEMENTS

CONOFLOW REGULATORS & CONTROLS

Division of ITT Grinnell Valve Co., Inc.

P.O. Box 768

St. George, S.C. 29477

(803) 563-9281 TELEX 805062